



DESIGNED TO BE USED WITH
AN EXPANSION JOINT COVER
TO CREATE A FIRE RATED ASSEMBLY

DESCRIPTION: WALL TO CORNER FIRE BARRIER
2 HOUR RATED UL ASSEMBLY #WW-D-1059/1060
5/8" TYPE X GYP.
REQUIRES EJ COVER
MOVEMENT: ± 50% JOINT WIDTH
STOCK LENGTHS: FIRE BARRIER 25'-0" ROLLS, METAL
MOUNTING FLANGES 10'-0"

P30-WC-02
REV. 03/10



**Architectural Art
MANUFACTURING**

Division of Pittcon Architectural Metals, LLC
283 SWANSON DRIVE, STE 103
LAWRENCEVILLE, GA 30043
PH: (678) 680-7373 FAX: (678) 735-0085
TOLL FREE: (800) 835-0028 web: www.archart.com

P Series Wall Fire Barrier

MODEL: P30-WC-02

DRAWN BY:
NDC

SCALE:
NTS
ISSUE DATE:
3/07/10

DRAWING NO.:

DTL-01

NO.	DESCRIPTION	BY	DATE

REVISIONS

The information contained herein is the proprietary property of **ARCHITECTURAL ART MFG.**, Division of Pittcon Architectural Metals, LLC. No portion of it may be reproduced by any means or used in any form except for the purpose for which it was furnished. All rights of design and invention are hereby reserved. We reserve the right to make changes in the design at our discretion.